



Foot-candles on floor

	<u>80°</u>	<u>60°</u>
<u>25' BOL</u>		
Average:	18.7	18.5
Maximum:	21	24
Minimum:	15	9
Avg:Min	1.25	2.06
Max:Min	1.40	2.67

	<u>80°</u>	<u>60°</u>
<u>35' BOL</u>		
Average:	17.9	18.0
Maximum:	20	20
Minimum:	13	14
Avg:Min:	1.38	1.29
Max:Min:	1.54	1.42

	<u>80°</u>	<u>60°</u>
<u>45' BOL</u>		
Average:	16.6	17.5
Maximum:	19	21
Minimum:	12	12
Avg:Min	1.39	1.46
Max:Min	1.58	1.75

	<u>80°</u>	<u>60°</u>
<u>60' BOL</u>		
Average:	15.0	16.6
Maximum:	19	19
Minimum:	10	11
Avg:Min:	1.50	1.51
Max:Min:	1.90	1.72

All Rooms: Dimensions: 100x100'; Ceiling Heights 65'; Reflectivity 80/50/20% (ceiling/walls/floor); Luminaire Spacing 25x25'